

**PWSD # 10 Regulated ~ Contaminants-Reseller Report**

Regulated Contaminants	Sample Year	Water System	Level Found	Range	Unit	MCL	MCLG	Typical Sources
BARIUM	2-18-2015	BOONE CO PWSD #10	0.0342	0.00919 0.0342	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	2009		4.09	3.82- 4.09	ppb	100	100	
FLUORIDE	2-18-2015	BOONE CO PWSD #10	1.6	1.21 - 1.6	ppm	4	4	Natural Deposits; Water additive which promotes strong teeth.

Secondary Contaminants	Sample Year	Water System	Level Found	Range	Unit	SMCL	MCLG	Typical Sources
ALKALINITY CACO3 STABILITY	2-18-2015	BOONE CO PWSD #10	340	315-340	MG/L ppm			
ALKALINITY, TOTAL	2-14-2006		315.5000	305-325	MGL ppm			
CALCIUM	2-18-2015	BOONE CO PWSD #10	66.9	63.6 - 66.9	MG/L ppm			
CHLORIDE	2-18-2015	BOONE CO PWSD #10	69	42 – 69	MG/L ppm	250		
HARDNESS CARBONATE	2-18-2015	BOONE CO PWSD #10	298	278 - 298	MG/L ppm			
IRON	2-18-2015	BOONE CO PWSD #10	0.0563	0.00998- 0.0563	MG/L ppb	0.3		
MAGNESIUM	2-18-2015	BOONE CO PWSD #10	32	28.9- 32	MG/L ppm			
MANGANESE	2-18-2015	BOONE CO PWSD #10	0.00238	0.00204- 0.00238	MG/L ppb	0.05		
PH	2-18-2015	BOONE CO PWSD #10	7.4	7.26- 7.4	PH	8.5		
POTASSIUM	2-18-2015	VV	11.7	9.19- 11.7	MGL ppm			

*In the following tables, you will find many terms and abbreviations that you may not be familiar with. To better help you understand these terms, we have provided the following definitions:*

**90<sup>th</sup> percentile:** For lead and Copper testing. 10% of test results are above this level and 90% are below this level.

**Level found:** is the average of all test results for a particular contaminate

**Range of Detections:** Shows the lowest and highest levels found during a testing period, if only one sample was taken then this number equals the Level Found.

**Parts per million (ppm) or Milligrams per liter (mg/l)**

**Parts per billion (ppb) or Micrograms per liter**

**n/a: not applicable**

**Picocuries per liter (pCi/L)** – Picocuries per liter is a measure of the radioactivity in water.

**AL: Action Level** – The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

**Maximum Contaminant Level** – The “Maximum Allowed” (MCL) is the highest level of contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** – The “Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG’s allow for a margin of safety.

**TT - Treatment Technique**

**NTU: Nephelometric Turbidity Unity** – Used to measure cloudiness in drinking water.

**MFL or Million Fibers Per Liter** – Used to measure asbestos concentration

**ND** – Not detectable at testing limits

**Missouri Department of Natural Resources** – State of Missouri regulatory agency that oversees the monitoring regulation of public drinking water systems.

**The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records marked with \*, though representative, are more than one year old.**

## WHY ARE THERE CONTAMINANTS IN MY WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

### Contaminants that may be present in source water include:

1. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
2. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
3. Pesticides and herbicides, which may come from a variety of sources such as agricultural, urban storm water runoff, and residential uses.
4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
5. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Missouri Department of Natural Resources prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Missouri Department of Health regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day for a lifetime at the MCL level to have a one-in-a-million chance of having the described health effect.

### Uncorrected Significant Deficiencies

Date Identified	Facility	Category Code	Comments
N/A	PWS ID #MO 3010771	N/A	N/A

## DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections.

These people should seek advice about their drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

The elected officials and employees of the City of Sturgeon work to provide top quality water to every tap. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please call our office at (573) 687-3321 if you have questions.

### How might I become actively involved?

If you would like to observe the decision-making process that affect drinking water quality or if you have any further questions about your drinking water report, please call us at 573-682-5314 (PSW 10) to inquire about scheduled meetings or contact persons

*Sincerely yours,*

*Gene D Kelly  
Mayor*

- City of Sturgeon ~ (573) 687-3321
- PWSD # 10 ~ (573) 682- 5314
- Safe Drinking Water Hotline ~ (800) 426-4791

**Special Lead and Copper Notice:** If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mosby is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://water.epa.gov/drink/info/lead/index.cfm>.

# City of Sturgeon

## 2015 Annual Water Quality Report (Consumer Confidence Report)

This report is intended to provide you with important information about your drinking water and the efforts made to provide safe drinking water.

The City of Sturgeon monitors for contaminants in your water according to Federal and State laws and is pleased to report that there were no violations according to their requirements.

This report is for the period of January 1, 2014 through December 31, 2015.

If you have questions regarding this report, please contact John Gingerich at: (573) 687-3321.

If you want to learn more about this report, you may attend a city council meeting, which is regularly scheduled for the fourth Monday of each month beginning at 7:00 p.m. at the Sturgeon City Offices.

### WHAT IS THE SOURCE OF MY WATER?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

The City of Sturgeon purchases the water from Boone County PWSD #10 (I.D. # MO 3024059) with wells located at the following locations: (573) 682-5314

- Well #1 . . . . . T.51N, R11W. Sec. 29 1375' in depth
- Well #2 . . . . . T.51N, R11W. Sec. 29 1380' in depth
- Well #3 . . . . . T.51N, R11W. Sec. 08 1400' in depth
- Well #4 . . . . . T.51N, R11W. Sec. 20 1500' in depth

### PWSD # 10 Regulated ~ Contaminants-Reseller Report

Regulated Contaminants	RESULT	Water System	Level Found	Range	Unit	MCL	MCLG	Sources of Nitrate
NITRATE (ASN)	<0.05	BOONE CO PWSD 10			Mg/L	10		Run off from fertilizer, leaching from septic tanks, erosion of natural

### PWSD #10 Contaminants

Secondary Contaminants	Sample Year	Water System	Level Found	Range	Unit	SMCL	MCLG	Typical Sources
SODIUM	2-18-2015	BOONE CO PWSD #10	82.4	54.1- 82.4	MG/L ppm			
SULFATE	2-18-2015	BOONE CO PWSD #10	70.7	45.9- 70.7	MG/L ppm	250		
SOLIDS TOTAL DISSOLVED (TDS)	2-18-2015	BOONE CO PWSD #10	495	415- 495	MG/L ppm	500		
ZINC	2-18-2015	BOONE CO PWSD #10	0.0699	0.0197- 0.0699	MG/L ppb	5		

During the 2014 calendar year, the water system(s) that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
BOONE CO PWSD #10	NO VIOLATIONS OCCURRED IN CALENDAR YEAR OF 2014			

Radionuclide	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Gross Alpha Particle Activity, total	8/21/2013	7.9	5.5-7.9	pCi/l			Erosion of Natural Deposits

Radionuclide	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Combined Radium (-226 & -228)	8/21/2013	2	1.5-2	pCi/l	5		Erosion of Natural Deposits

Radionuclide	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Radium-226	8/21/2013	2	1.5-2	pCi/l	5		Erosion of Natural Deposits

Copper	90 <sup>th</sup> percentile	Range of Results (low-high)	Unit	AL	Sites Over AL	Typical Source			
2011-2013	0.128	0.0268-0.184	ppm	1.3	0	Corrosion of household plumbing system			

Lead	90 <sup>th</sup> percentile	Range of Results (low-high)	Unit	AL	Sites Over AL	Typical Source			
2011-2013	7.1	1.02-12.8	ppb	15	0	Corrosion of household plumbing system			

**Coliform**

# POSITIVE SAMPLES	% POSITIVE SAMPLES	MONTH	VIOLATION
0	0	N/A	NO

The MCL for total Coliform is determined by the number of samples taken per month. Systems that collect **less than 40** samples per month are in violation **IF** more than **ONE** sample tests positive. Systems that collect **more than 40** samples per month are in violation **if 5% or more** of the samples test positive.

**Fecal Coliform**

# POSITIVE SAMPLES	% POSITIVE SAMPLES	MONTH	VIOLATION
0	0	N/A	NO

The MCL for Fecal Coliform is where a routine sample and a repeat sample are total coliform positive and one is also fecal coliform or E. Coli positive.  
**SOURCE:** Naturally present in the environment

**Unregulated Contaminants**

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Information on all the contaminants that were monitored for, whether regulated or unregulated, can be obtained from this water system or The Department of Natural Resources.

**Unregulated**

INORGANIC	UNITS	LEVEL FOUND	RANGE OF DETECTION
Nickel Dissolved	Ppb	4.213	3.76 – 4.58

**Violations and Health Effects Information**

There were no MLC, Monitoring, or treatment technique violations for this report.  
**NO VIOLATIONS OCCURRED IN CALENDER YEAR 2014**



*2015 ~ Annual Water Quality Report*  
**PWS ID #MO 3010771**